

Grady, Mark

From: Lucier, Eric
Sent: Saturday, February 02, 2013 4:05 PM
To: harding.george@epa.gov; Muhammad.Ahsan@state.ma.us; dbuske@techenv.com; Frank Giacalone
Cc: Hughes, Matt; Grady, Mark; Gosine, Jairaj
Subject: Wheelabrator Saugus Inc.

Wheelabrator Saugus Inc. is providing a courtesy notification of downtime associated with the temporary loss of our river water intake #2 travelling screen. On February 2, 2013 at approximately [08:00](#) the #2 travelling screen located in the river water intake pump house was discovered to be off its' track, and thus unable to run. The previous inspection of the screens was performed at 22:00 on February 1, 2013. No problems were noted during that inspection. Due to the configuration of the screen it will be necessary to have a service contractor conduct repairs. Please note, the #1 travelling screen operation is not affected by this condition, and will continue to operate automatically for at least 15 minutes for every 30 minutes of time.

A service contractor will attempt to make repairs to the system on Monday, February 4th. Per the permit requirement, inspections of the travelling screens are performed once per shift.

Please feel free to contact me if you have any questions or comments on this notification.

Regards,

Eric Lucier